

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Yes. Structures built after the state lead ban of January 1, 1988, can be classified as non-lead.

How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can water sampling be used to help classify service line materials?

It is important to note that water quality sampling is a more appropriate screen for the presence of LSLs since low and non-detect lead levels may not reliably indicate the absence of LSLs. The key to using water quality sampling for identifying LSLs is establishing a community-specific threshold to indicate the possible presence of an LSL.

Can predictive modeling be used to help classify service line materials?

Any use of predictive modeling will have to be pre-approved by the NDDEQ. If approved, the PWS will need to explain and provide details about the inputs used for the model in the space provided.

For North Dakota Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Guidance](#)
- [DWSRF Funding Resources](#)



POPULATION :

779,702

OF CWS :

308

#NTNCWS :

6

**#CWS SERVING
<10,000 POPULATION :**

298

**%CWS SERVING
<10,000 POPULATION :**

97%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

273,201

ESTIMATED LSLS :

26,443

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$28,650,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER
QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™