

SERVICE LINE INVENTORY Q&A



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on build date?

Yes, service lines installed after 9/12/1988 are considered non-lead because this is when the state lead ban was enacted.

How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can service lines >2 inches be classified as non-lead?

Yes, any service line with a diameter of 2 inches or greater can be categorized as non-lead.

Can the inventory be submitted in different formats?

Water systems may export data from other databases and map the data to OH inventory requirements. Instructions for this process are listed in the "Instructions for Service Line Template" in the resources below.

Does Ohio allow water sampling and predictive modeling as verification methods?

Yes, but systems should ensure that those verification processes are well documented and align with industry best practices.

For Ohio Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Instructions for Service Line Template](#)
- [Service Line Inventory Fact Sheet](#)
- [Service Line Inventory FAQ](#)
- [DWSRF Funding Resources](#)



POPULATION :
11,808,848

OF CWS :
1148

#NTNCWS :
607

#CWS SERVING
<10,000 POPULATION :
988

%CWS SERVING
<10,000 POPULATION :
86%

POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :
1,585,490

ESTIMATED LSLS :
745,061

BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :
\$166,913,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM

For sources, refer to 120Water.com/regulations



120Water™