

# SERVICE LINE INVENTORY



## When is the initial inventory due?

The due date is October 16, 2024.

## Can service lines be classified as non-lead based on install/build date?

Yes, structures built after the state lead ban of July 1, 1989 can be classified as non-lead.

## How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

## Why are there 3 different templates?

Systems that serve multiple buildings, such as a fire district or municipality use the [multi-building template](#). Those systems that serve a single building with no accessory water use, such as a single-building school or a condominium association all under a single roof, use the [single-building inventory template](#). Any water system that has service connections for non-potable water, such as fire protection or other non-drinking purposes ALSO need to complete the [non-potable inventory template](#) for those non-potable connections and submit BOTH completed inventories to the Division.

## Can water sampling be used to help classify service line materials?

Water sampling has the potential to identify service line materials. Systems wanting to use this method should get approval from the state prior to starting a sampling program.

### For Vermont Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [Service Line Inventory Templates](#)
- [Service Line Inventory Guidance](#)
- [Service Line Inventory FAQ](#)
- [Service Line Inventory Submission Guidance](#)
- [Service Line Inventory Training Slides](#)
- [DWSRF Funding Resources](#)



**POPULATION :**

**643,503**

**# OF CWS :**

**411**

**#NTNCWS :**

**252**

**#CWS SERVING  
<10,000 POPULATION :**

**404**

**%CWS SERVING  
<10,000 POPULATION :**

**98%**

**POPULATION SERVED BY  
SYSTEMS SERVICE <10,000 :**

**335,028**

**# ESTIMATED LSLS :**

**5,263**

**BIPARTISAN INFRASTRUCTURE  
LAW DWSRF LEAD SERVICE LINE  
REPLACEMENT ALLOCATION :**

**\$28,650,000**



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER  
QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™