

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Yes, structures built after the lead ban of 1/1/1986 can be classified as non-lead.

Can service lines be classified as non-lead based on diameter?

Yes, any service line with a diameter of 2 inches or greater can be classified as non-lead.

How are lead goosenecks considered for service line definitions?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

When will the inventory template be available through the DNR website?

DNR is anticipating posting the templates and additional guidance documentation to the website in the resources section later in 2023.

Are their different templates for CWS and NTNCWS?

Yes, DNR has a simplified template for NTNCWS.

For Wisconsin Service Line Inventory Resources, click the links below.

- [LCR and Service Line Inventory Website](#)
- [DWSRF Funding Resources](#)



POPULATION :
5,897,473

OF CWS :
1,030

#NTNCWS :
888

#CWS SERVING
<10,000 POPULATION :
942

%CWS SERVING
<10,000 POPULATION :
91%

POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :
1,076,171

ESTIMATED LSLS :
341,023

BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :
\$81,203,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER
QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™