

SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

Can service lines be classified as non-lead based on install/build date?

Yes, structures built after the state lead ban of April 1, 1987 can be classified as non-lead.

How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement.

Can service lines be classified as non-lead based on diameter?

If the service line is 2-inches or greater, then it is likely non-lead.

Can predictive modeling or water sampling be used for material classification?

Systems should consult with the State for approval prior to using predictive modeling or water sampling to classify service line materials.

For New Mexico Service Line Inventory Resources, click the links below.

- [Service Line Inventory Website](#)
- [Service Line Inventory Template](#)
- [Service Line Inventory Guidance](#)
- [DWSRF Funding Resources](#)



POPULATION :

2,120,220

OF CWS :

564

#NTNCWS :

131

**#CWS SERVING
<10,000 POPULATION :**

532

**%CWS SERVING
<10,000 POPULATION :**

94%

**POPULATION SERVED BY
SYSTEMS SERVICE <10,000 :**

433,080

ESTIMATED LSLS :

15,453

**BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION :**

\$28,650,000



FOR MORE INFORMATION CONTACT 120WATER DIRECTOR OF WATER
QUALITY COMPLIANCE, JONATHAN.CUPPETT@120WATER.COM



120Water™