
SERVICE LINE INVENTORY



When is the initial inventory due?

The due date is October 16, 2024.

How can service line inventory resources be accessed?

Water systems can access the inventory template and other helpful resources through the "Service Line Inventory Website" link in the resources section. Systems will need to create a user name and password to access the materials.

Can service lines be classified as non-lead based on install/build date?

If you have documentation that a structure was built after 1987, or the local date accepted for the lead installation ban, the customer survey or further investigation is not necessary if the water system has documentation to verify the private service line is not lead or galvanized requiring replacement.

How are lead goosenecks being considered?

Lead goosenecks are NOT considered a source of lead in the definitions of lead service lines or galvanized requiring replacement. However, systems must complete the lead gooseneck/connector field in the template.

Can service lines be classified as non-lead based on diameter?

Service lines >2 inches can typically be classified as non-lead but water systems need to have confidence in their records.

Are public water supplies required to use the template provided by DANR for the lead service line inventory, or can they create their own?

Water systems are required to use the template provided by DANR, unless prior permission is granted by DANR to utilize an alternate method.

For South Dakota Service Line Inventory Resources, click the links below.

• Service Line Inventory Website



POPULATION:

887,770

OF CWS:

464

#NTNCWS:

17

#CWS SERVING <10,000 POPULATION:

446

%CWS SERVING <10,000 POPULATION:

96%

POPULATION SERVED BY SYSTEMS SERVICE <10,000:

325,212

ESTIMATED LSLS:

4.141

BIPARTISAN INFRASTRUCTURE
LAW DWSRF LEAD SERVICE LINE
REPLACEMENT ALLOCATION:

\$28,650,000



